


Abwasserverband Ager-West Kläranlage

Ablaufwerte 2023

		Ablaufwerte gemäß Wasserrechtsbescheid WA-2009-100593/275-Wab/Gin						
		BSB ₅		CSB		NH ₄ -N		gesN
Jahreswerte	max 15 mg/l	mind 95%	max 75 mg/l	mind 85%	bei 8°C < T < 12°C max 5 mg/l	bei T > 12°C max 3 mg/l	mind. 70 % bei T > 12°C im Jahresmitte	max 1,0 mg/l im Jahresmittel
	mg/l	%	mg/l	%	mg/l	mg/l	%	mg/l
Minimum	2,0	93,3	13,0	90,1	0,6	0,6	65,3	0,1
Maximum	18,0	99,3	37,0	97,3	3,3	3,0	90,3	1,2
Mittelwert	5,9	97,9	25,4	95,2	1,3	1,5	78,2	0,4
Anzahl der Werte	318	318	318	318	123	194	64	231

Hinsichtlich der Einhaltung der Emissionsbegrenzungen gilt § 4 der 1. AEW für kommunales Abwasser vgm 7.5.1996


Abwasserverband Ager-West
 Ahamer Straße 63
 A-4800 Attnang-Puchheim
 Tel. 07674-64580 Fax Nr. 9



Abwasserverband Ager-West
 Ahamer Straße 63
 A-4800 Attnang-Puchheim
 Tel. 07674-64580 Fax Nr. 9



Abwasserverband Ager-West
 Obmann Bgm. Peter Gröbels
 Ahamer Straße 63
 A-4800 Attnang-Puchheim
 Tel. 07674-64580 Fax Nr. 9
